



**CITY OF ROCKVILLE**  
Procurement Division  
111 Maryland Avenue  
Rockville, Maryland 20850-2364  
Phone 240-314-8430 Fax 240-314-8439

### **ADDENDUM 1**

**DATE:** August 15, 2016

**REFERENCE:** City of Rockville  
Invitation for Bid:

**IFB 02-17**  
**Accessible Pedestrian Signals Project**

**Scheduled Submittal Deadline:** Tuesday, August 23, 2016 at 2:00 P.M. (Eastern)

---

**Please note; we have received the following questions/comments concerning this Invitation for Bid. Responses to these questions are also provided, where additions, revisions, clarifications, corrections and/or deletions found within the City's response are incorporated into this Addendum:**

- 1) Would it be possible to get a drawing detail of Items:

8025 5' DECORATIVE STEEL PEDESTRIAN PEDESTAL POLE  
8026 10' DECORATIVE STEEL PEDESTRIAN PEDESTAL POLE

I have read the written specifications on pages 64 and 65 but I can't find a style of decorative pedestal base required. Please let me know if this information is available and where I might find it.

**RESPONSE:**

**The City does not have the drawing details for the items 8025 and 8026. The City uses a painted aluminum octagonal base assembly in the City. For your information, the City approved the Pelco's PB-5349 for the previous constructions.**

Please sign below to acknowledge receipt of addendum and return with your bid.

Sincerely,

Jonathan Pierson, CPSM, C.P.M.  
Principal Buyer

---

Company Name

---

Authorized Signature

---

Date

JWP/jwp